



Steven L. Beshear
Governor

Leonard K. Peters
Secretary
Energy and Environment Cabinet

Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

David L. Armstrong
Chairman

James Gardner
Vice-Chairman

John W. Clay
Commissioner

July 24, 2008

Mr. James A. Carr, Chairman
Madison County Utility District
PO Box 670
Richmond, KY 40476-0670

Honorable Chuck Hardin
Robbins Law Office
214 N. 3rd Street
Richmond, KY 40475

Mr. Kerry S. Odle, P.E.
CMW, Inc.
PO Box 831
138 N. Keeneland Dr., Suite E
Richmond, KY 40475

RE: Case No. 2008-00182
Madison County Utility District

Gentlemen:

The Commission staff has reviewed your response and has determined that your application in the above case now meets the minimum filing requirements. Enclosed please find a stamped filed copy of the first page of your filing. This case has been docketed and will be processed as expeditiously as possible.

If you need further assistance, please contact James Rice at 502-564-3940.

Sincerely,

A handwritten signature in cursive script that reads "David R. McDowell".

David R. McDowell
Divisions of Filings

RECEIVED

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

MAY 22 2008

PUBLIC SERVICE
COMMISSION

In the matter of:

APPLICATION OF THE MADISON COUNTY)
UTILITIES DISTRICT FOR A CERTIFICATE OF)
PUBLIC CONVENIENCE AND NECESSITY)
TO CONSTRUCT A WATER STORAGE TANK)
AND A GENERAL RATE INCREASE TO)
FINANCE WATER STORAGE TANK)

FILED
JUL 21 2008
PUBLIC SERVICE
COMMISSION

Case No. 2008-00182

APPLICATION

The Madison County Utilities District ("District") pursuant to KRS 278.020 petitions the Public Service Commission ("Commission") for a Certificate of Public Convenience and Necessity to construct a water storage tank and a General Rate Increase to Finance the Water Storage Tank. The following information is filed in accordance with the Commission's Regulations:

1. The District's office address is P. O. Box 670, 297 Michelle Drive, Richmond, Kentucky 40476-0670. Its principal officers are listed in its 2006 Annual Report which is on file with the Commission.
2. The District is a non-profit water organized under KRS Chapter 74 and has no separate Articles of Incorporation or By-Laws.
3. Madison County Utilities District currently has 1,600,000 gallons of storage within the District. From 3/1/07 to 2/28/08 the District purchased an average of 1,909,300 gallons per day and sold an average of 1,692,700 gallons per day. The District has previously been cited in PSC inspection report of not having adequate storage. This project will add 400,000 gallons of storage by constructing a 500,000 gallon elevated water storage tank and taking a 100,000 gallon elevated water storage tank out of service. The 100,000 gallon tank was constructed in the 1960's and based on tank inspection, the repairs would exceed the value of the tank.